
HR-MAX - mounting instructions



1. HR-MAX lighting fixture

Inspiring


KLUŚ

- Foam*
- 3. Cable for a 12 V / 24 V power supply**
- 4.1 Hermetic coupler (item 4.1)*
- 4.2 Hermetic coupler (item 4.2)*
- 4.3 Hermetic coupler (item 4.3)*
- 5.1 Connector (item 5.1)*
- 5.2 Connector (item 5.2)*

*The full range of accessories and electronics is available at www.KlusDesign.eu **Use a cable with circular insulation and an outer diameter of not less than 6 mm / 0.24" and not more than 9 mm / 0.35".

NOTE! The fixture comes with a Z-type fastener. A damaged external flexible conductor in this fixture cannot be replaced. In the event of damage to the external flexible conductor, the fixture must be disposed. The light source of this fixture is not replaceable; when the light source is worn out, the entire lighting fixture must be replaced.


IMPORTANT: Not all possible mounting procedures are presented here. More mounting procedures and related accessories can be found at www.KlusDesign.eu. Drawings of profiles and accessories in these instructions are simplified and only approximate the actual shapes.



1.7 Nm


www.KlusDesign.eu





www.KlusDesign.eu

KLUŚ Inspiring Solutions



KLUŚ Inspiring Solutions



HR-MAX - mounting instructions

